


Tablet Placement Instructions


bimaks

FOR AIR CONDITIONING SYSTEMS




VERTICAL OR HORIZONTAL COIL

When there is sufficient space between coil and drain pan.
Clean condensate drain pan before placing the tablet.
Place tablet (unit) under cooling coil in the middle of pan length.
Tablet must be in contact with condensate.



"A" SHAPED COIL OR SLANT COIL

When the space between coil and drain pan is too small.
Clean condensate drain pan before placing the tablet.
Place tablet (unit) on its side between coil and pan edge in the middle of pan length.



LARGE AIR CONDITIONING UNIT

When there is sufficient space between coil and drain pan.
Clean condensate drain pan before placing the tablet.
Place tablet (unit) under cooling coil in the middle of pan length.
Tablet must be in contact with condensate.
Use multiple tablets for larger air conditioning systems.

DO NOT USE IN: HUMIDIFIERS, HUMIDIFIER SECTION OF AIR CONDITIONING SYSTEMS OR EVAPORATIVE COOLERS. DO NOT PLACE TABLETS (UNITS) IN DRAIN PANS ABOVE FOOD PRODUCTS.

STORE: STORE UNUSED TABLETS IN THEIR ORIGINAL CONTAINER AT ROOM TEMPERATURE.

Always read the label and safety data sheet before use.

Bimaks NZ Ltd

Contact: Yeliz A. Stevens

Telephone: 02102403888